

**Recommended Citations
West Dig Contractors Inc.
#307794511**

Rule/Standard	Classification	Description	Proposed Penalty
408.40941(1)	Willful/Serious	Excavation sides not properly supported or sloped to prevent cave-in.	\$70,000
408.42223(2)	Willful/Serious	Failure to use proper traffic control.	\$70,000
408.40933(2)	Serious	Failure to store spoils 2 Ft. back from edge of excavation	\$5,000
408.42223(8)	Serious	No traffic vest with reflective material used for traffic control	\$5,000
408.40624(3)	OTS	Improper eye protection	\$0
408.40625(2)	OTS	Improper foot protection	\$0
408.42223(4)	OTS	Improper traffic regulator paddle sign	\$0